

## **SECTION 6**

### **6.21 METER BYPASS LINES:**

A bypass line shall be required for all meters 1-1/2 inch and larger, unless otherwise specified by Denver Water, whether installed in an outside or inside setting. Bypass lines shall contain an independent control valve and shall contain no tees, plugs, or other outlets through which water could be withdrawn. Bypass lines permit the consumer to have water while his/her meter is being repaired or replaced.